



***ALL METALS
Analysis Report**

Submitter ID # (PWS ID #): 1050135

LSR WSC
KUYKENDALL, JIM
PO BOX 1404
WIMBERLEY, TX 78676-1404

Date Reported : 07/17/2025
Report ID# : 20250717084549AH32336

Lab Sample ID# : AH32336 Water Source :
Sample Priority : NORMAL Entry Point(s) : EP001
TCEQ Sample ID: 2514457

Date Collected : 07/01/2025 10:11
Date Received : 07/02/2025

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	07/02/2025	AH
pH Check	Completed		EPA 200.2	07/03/2025	SN
Turbidity Screen	Completed		SM 2130B	07/03/2025	SN
Visible Particles	Completed			07/03/2025	SN
Total Hardness as CaCO3 by Calculation	325	mg/L	SM 2340B	07/09/2025	AD
Aluminum ¹	< 0.0200	mg/L	EPA 200.8	07/03/2025	ME
Antimony ¹	< 0.0010	mg/L	EPA 200.8	07/03/2025	ME
Arsenic ¹	< 0.0020	mg/L	EPA 200.8	07/03/2025	ME
Barium ¹	0.0284	mg/L	EPA 200.8	07/03/2025	ME
Beryllium ¹	< 0.00080	mg/L	EPA 200.8	07/03/2025	ME
Cadmium ¹	< 0.0010	mg/L	EPA 200.8	07/03/2025	ME
Calcium	108	mg/L	EPA 200.7	07/09/2025	AD
Chromium ¹	< 0.0100	mg/L	EPA 200.8	07/03/2025	ME
Copper ¹	0.0034	mg/L	EPA 200.8	07/03/2025	ME
Iron ¹	< 0.010	mg/L	EPA 200.7	07/09/2025	AD
Lead ¹	< 0.0010	mg/L	EPA 200.8	07/03/2025	ME
Magnesium ¹	13.5	mg/L	EPA 200.7	07/09/2025	AD
Manganese ¹	< 0.0010	mg/L	EPA 200.8	07/03/2025	ME
Mercury ¹	< 0.00040	mg/L	EPA 245.1	07/09/2025	AH
Nickel ¹	0.0023	mg/L	EPA 200.8	07/03/2025	ME
Potassium ¹	< 1.00	mg/L	EPA 200.7	07/09/2025	AD
Selenium ¹	< 0.0030	mg/L	EPA 200.8	07/03/2025	ME
Silver ¹	< 0.0100	mg/L	EPA 200.8	07/03/2025	ME
Sodium ¹	13.4	mg/L	EPA 200.7	07/09/2025	AD
Thallium ¹	0.00055	mg/L	EPA 200.8	07/03/2025	ME
Zinc ¹	0.0074	mg/L	EPA 200.8	07/03/2025	ME

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(¹) meet all TNI (2016 Standard) requirements.

Authorized by Team Lead KLE on 07/15/2025